

**PUBLIC NOTICE-CUSTOMERS OF
MAYSVILLE PWS
FAILURE TO MEET MICROBIOLOGICAL MONITORING
REQUIREMENTS FOR DRINKING WATER**

Este informe contiene information muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During **November 2024**, we did not properly meet all monitoring requirements for total coliform bacteria, and therefore, cannot be sure of the quality of our drinking water during that time. This is a violation of Missouri Public Drinking Water Regulations.

Although this incident was not an emergency, as our customers you have a right to know what happened and what we did to correct the situation. Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or by distributing copies by hand or mail.

Provide explanation of cause of monitoring failure:

Lack of communication during employee transition at the Water Plant caused this testing to be overlooked before the deadline passed.

For more information, please contact water system staff indicated below:

Joshua Mygatt at 816-449-2185 or P.O. Box 470 Maysville, MO 64469
(name of water system contact) (phone number) (mailing address)

Additionally, you may contact the Missouri Department of Natural Resources' Kansas City Regional Office at 816-251-0700 or Public Drinking Water Branch at 573-526-6925.

This notice is being sent to you by MAYSVILLE PWS
State Water System ID#: MO1010510