



**MISSOURI**  
DEPARTMENT OF  
NATURAL RESOURCES

Michael L. Parson  
Governor

Dru Buntin  
Director

---

BOIL WATER ORDER LIFTED  
MAYSVILLE PWS  
1304 SOUTH POLK, MAYSVILLE, MO  
MO1010510

CANCELACIÓN DE LA ORDEN DE HERVIR AGUA

*Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.*

On August 29, 2024, the Missouri Department of Natural Resources issued a boil water order for the Maysville Public Water System (PWS), MO1010510, located at 1304 S Polk, Maysville, Dekalb County. Finished water turbidity level were above 1 nephelometric turbidity unit (NTU) on August 5 and 6, 2024. In addition, the City of Maysville failed to meet the minimum disinfection residual entering the distribution system for chloramines of 1.00 mg/L (measured as total chlorine) on August 1, 2024, and August 9th through 12th 2024 in accordance with 10 CSR 60-4.055(3). During a follow-up visit conducted by MRWA and department team member (s) on August 28, 2024, finished water turbidity was observed again above 1 NTU (1.6 NTU observed).

The department lifted the boil water order on December 20, 2024, after the system obtained turbidity measurements below 0.3 NTU in 95% of the samples taken during a 30-day running average from November 20, 2024, to December 19, 2024. Bacteriological samples taken from the distribution system on December 16, 2024, and December 17, 2024, were bacteriologically safe and disinfection residuals were compliant with all maximum residual disinfectant levels (MRDLs). This showed that the water is again safe to drink. It is no longer necessary to boil your water.

For more information, please call Pat Fisher at 816-449-2185 or the Missouri Department of Natural Resources at 816-251-0700.

